

## **Svetlotehnički proračun**

Dogradnja pogonske zgrade UPOV-a - Laboratorij

pr.br.: 254-06-2017P

Partner for Contact:

Order No.:

Company:

Customer No.:

Date: 26.06.2017

Operator:

Operator  
Telephone  
Fax  
e-Mail

## Table of contents

---

### **Svetlotehnički proračun**


Project Cover	1
Table of contents	2
Luminaire parts list	3
<b>AWEX LVPU/2W/B LVPU/2W/B</b>	
Luminaire Data Sheet	4
<b>PHILIPS RC120B LED37S/840 W60L60 VAR-PC</b>	
Luminaire Data Sheet	5
<b>PHILIPS DN130B D217 1xLED20S/840</b>	
Luminaire Data Sheet	6
<b>Laboratorij</b>	
Summary	7
<b>Uklopnica</b>	
Summary	8
<b>Kupaonica</b>	
Summary	9
<b>Garderoba za čisto rublje</b>	
Summary	10
<b>Spremište</b>	
Summary	11
<b>Dnevni boravak</b>	
Summary	12
<b>Mikrobiologija</b>	
Summary	13
<b>Kemija</b>	
Summary	14
<b>Ured</b>	
Summary	15
<b>Hodnik i stubište</b>	
Summary	16
<b>Uklopnica - panika</b>	
Light scenes	
Light scene 1	
Room Surfaces	
Anti-panic Surface 1	
Value Chart (E, Perpendicular)	17

Operator  
Telephone  
Fax  
e-Mail


## Svetlotehnički proračun / Luminaire parts list

- 1 Pieces AWEX LVPU/2W/B LVPU/2W/B  
Article No.: LVPU/2W/B  
Luminous flux (Luminaire): 0 lm  
Luminous flux (Lamps): 0 lm  
Luminaire Wattage: 0.0 W  
Emergency Lighting: 280 lm, 2.0 W  
Luminaire classification according to CIE: 100  
CIE flux code: 54 93 99 100 100  
Fitting: 1 x LVPU/2W/B (Correction Factor 1.000).

See our luminaire catalog for an image of the luminaire.




- 12 Pieces PHILIPS DN130B D217 1xLED20S/840  
Article No.:  
Luminous flux (Luminaire): 2275 lm  
Luminous flux (Lamps): 2500 lm  
Luminaire Wattage: 22.0 W  
Luminaire classification according to CIE: 100  
CIE flux code: 61 91 98 100 91  
Fitting: 1 x LED20S/840/- (Correction Factor 1.000).



- 18 Pieces PHILIPS RC120B LED37S/840 W60L60 VAR-PC  
Article No.:  
Luminous flux (Luminaire): 3693 lm  
Luminous flux (Lamps): 3700 lm  
Luminaire Wattage: 31.0 W  
Luminaire classification according to CIE: 100  
CIE flux code: 82 96 99 100 100  
Fitting: 1 x LED37S/840 (Correction Factor 1.000).

See our luminaire catalog for an image of the luminaire.




Operator  
Telephone  
Fax  
e-Mail

## AWEX LVPU/2W/B LVPU/2W/B / Luminaire Data Sheet

See our luminaire catalog for an image of the luminaire.

### Luminous emittance 1:



Luminaire classification according to CIE: 100  
CIE flux code: 54 93 99 100 100

### Luminous emittance 1:

Glare Evaluation According to UGR											
Room Size X Y	Viewing direction at right angles to lamp axis						Viewing direction parallel to lamp axis				
	70	70	50	50	30	70	70	50	50	30	30
p Ceiling	70	70	50	50	30	70	70	50	50	30	30
p Walls	50	30	50	30	30	50	30	50	30	30	30
p Floor	20	20	20	20	20	20	20	20	20	20	20
2H	25.7	26.9	26.0	27.2	27.4	33.9	35.1	34.2	35.4	35.6	35.6
3H	26.6	27.6	26.9	27.9	28.1	34.0	35.1	34.3	35.4	35.6	35.6
4H	27.0	28.0	27.3	28.3	28.5	34.0	35.0	34.3	35.3	35.6	35.6
6H	27.4	28.3	27.6	28.6	28.9	34.0	34.9	34.3	35.2	35.5	35.5
8H	27.5	28.4	27.9	28.7	29.0	33.9	34.8	34.3	35.1	35.4	35.4
12H	27.5	28.3	27.9	28.7	29.0	33.9	34.7	34.3	35.0	35.4	35.4
4H	26.6	27.6	27.0	27.9	28.2	33.8	34.8	34.1	35.1	35.4	35.4
3H	28.0	28.8	28.4	29.1	29.5	34.0	34.9	34.4	35.2	35.5	35.5
4H	28.7	29.4	29.0	29.7	30.1	34.0	34.8	34.4	35.1	35.5	35.5
6H	29.2	29.8	29.6	30.2	30.6	34.0	34.6	34.4	35.0	35.4	35.4
8H	29.3	29.9	29.7	30.3	30.7	34.0	34.6	34.4	34.9	35.4	35.4
12H	29.3	29.8	29.8	30.2	30.7	34.0	34.5	34.4	34.9	35.3	35.3
8H	29.3	29.9	29.7	30.3	30.7	34.1	34.6	34.5	35.0	35.4	35.4
4H	30.1	30.6	30.6	31.0	31.5	34.1	34.5	34.5	35.0	35.4	35.4
6H	30.2	30.7	30.7	31.1	31.6	34.0	34.5	34.5	34.9	35.4	35.4
12H	30.2	30.6	30.7	31.1	31.6	34.0	34.4	34.5	34.8	35.3	35.3
4H	29.3	29.8	29.8	30.2	30.7	34.1	34.6	34.5	35.0	35.4	35.4
6H	30.2	30.6	30.6	31.0	31.5	34.1	34.5	34.5	34.9	35.4	35.4
8H	30.3	30.7	30.8	31.1	31.6	34.0	34.4	34.5	34.9	35.4	35.4

Variation of the observer position for the luminaire distances S

S = 1.0H	+1.5 / -2.6	+1.4 / -2.3
S = 1.5H	+3.5 / -3.9	+3.0 / -3.1
S = 2.0H	+5.0 / -4.7	+4.9 / -6.3

Standard table BK02

Correction Summand 20.1

BK01

22.9


Corrected Glare Indices referring to 280lm Total Luminous Flux

Operator  
Telephone  
Fax  
e-Mail

## PHILIPS RC120B LED37S/840 W60L60 VAR-PC / Luminaire Data Sheet

See our luminaire catalog for an image of the luminaire.

### Luminous emittance 1:



Luminaire classification according to CIE: 100  
CIE flux code: 82 96 99 100 100

### Luminous emittance 1:

Glare Evaluation According to UGR											
	70	70	50	50	30	70	70	50	50	30	
p Ceiling	50	30	50	30	30	50	30	50	30	30	
p Walls	20	20	20	20	20	20	20	20	20	20	
p Floor	20	20	20	20	20	20	20	20	20	20	
Room Size X Y	Viewing direction at right angles to lamp axis						Viewing direction parallel to lamp axis				
2H	2H	11.9	12.8	12.2	13.0	13.2	10.0	10.8	10.2	11.0	11.2
	3H	12.9	13.7	13.3	13.9	14.2	11.3	12.0	11.6	12.3	12.5
4H	13.3	14.0	13.6	14.2	14.5	11.7	12.4	12.0	12.7	12.9	
6H	13.5	14.2	13.8	14.4	14.7	11.9	12.6	12.3	12.9	13.2	
8H	13.5	14.2	13.9	14.5	14.8	12.0	12.6	12.3	12.9	13.2	
12H	13.6	14.2	13.9	14.5	14.8	12.0	12.6	12.4	12.9	13.2	
4H	2H	12.0	12.8	12.3	13.0	13.3	10.3	11.0	10.6	11.3	11.6
	3H	13.2	13.8	13.5	14.1	14.4	11.8	12.4	12.1	12.7	13.0
4H	13.7	14.2	14.0	14.5	14.9	12.3	12.8	12.7	13.2	13.5	
6H	14.0	14.4	14.4	14.8	15.2	12.7	13.1	13.1	13.5	13.8	
8H	14.1	14.5	14.5	14.9	15.3	12.7	13.1	13.2	13.5	13.9	
12H	14.1	14.5	14.6	14.9	15.3	12.8	13.1	13.2	13.5	14.0	
4H	4H	13.7	14.1	14.1	14.5	14.9	12.5	12.9	12.9	13.2	13.6
	6H	14.1	14.4	14.6	14.9	15.3	12.9	13.2	13.3	13.6	14.1
8H	14.3	14.5	14.7	15.0	15.4	13.0	13.3	13.5	13.7	14.2	
12H	14.4	14.6	14.8	15.0	15.5	13.1	13.3	13.6	13.8	14.3	
4H	4H	13.7	14.1	14.1	14.5	14.9	12.5	12.8	12.9	13.2	13.6
	6H	14.1	14.4	14.6	14.8	15.3	12.9	13.2	13.4	13.6	14.1
8H	14.3	14.5	14.7	15.0	15.5	13.1	13.3	13.5	13.7	14.2	
12H	14.4	14.6	14.8	15.0	15.5	13.1	13.3	13.5	13.7	14.2	

Variation of the observer position for the luminaire distances S

S = 1.0H	+1.8 / -2.1	+1.9 / -2.0
S = 1.5H	+3.8 / -3.0	+3.9 / -2.6
S = 2.0H	+5.6 / -3.8	+5.6 / -3.1

Standard table Correction Summand


BK01	BK02
-6.0	-7.2

Corrected Glare Indices referring to 3700lm Total Luminous Flux

Operator  
Telephone  
Fax  
e-Mail

## PHILIPS DN130B D217 1xLED20S/840 / Luminaire Data Sheet

### Luminous emittance 1:



### Luminaire classification according to CIE: 100 CIE flux code: 61 91 98 100 91

CoreLine Downlight – The clear choice for LED The CoreLine Downlight range of recessed luminaires is designed to replace CFL-ni/CFL-i based downlight luminaires. Their attractive TCO helps customers to make the switch to LED. These luminaires create a natural lighting effect for use in general lighting applications. They also deliver instant energy savings and have a much longer lifetime, creating a real value-for-money and environmentally friendly solution. They are easy to install thanks to their standard cut-out size and push-in connectors.

### Luminous emittance 1:

Glare Evaluation According to UGR												
Room Size X Y	Viewing direction at right angles to lamp axis						Viewing direction parallel to lamp axis					
	70	70	50	50	30	70	70	50	50	30	70	70
p Ceiling	70	70	50	50	30	70	70	50	50	30	70	70
p Walls	50	30	50	30	30	50	30	50	30	30	50	30
p Floor	20	20	20	20	20	20	20	20	20	20	20	20
2H	25.6	26.6	26.0	26.9	27.1	25.6	26.7	25.9	26.9	27.1	25.6	26.7
3H	25.9	26.9	26.2	27.2	27.5	25.9	26.9	26.2	27.2	27.3	25.9	26.9
4H	26.1	27.0	26.4	27.3	27.6	26.1	27.0	26.4	27.3	27.6	26.1	27.0
6H	26.2	27.1	26.6	27.4	27.7	26.2	27.1	26.6	27.4	27.7	26.2	27.1
8H	26.3	27.1	26.6	27.4	27.7	26.3	27.1	26.6	27.4	27.7	26.3	27.1
12H	26.3	27.1	26.7	27.4	27.7	26.3	27.1	26.7	27.4	27.7	26.3	27.1
4H	25.7	26.6	26.0	26.9	27.2	25.7	26.6	26.0	26.9	27.2	25.7	26.6
3H	26.2	26.9	26.5	27.3	27.6	26.2	26.9	26.5	27.3	27.6	26.2	26.9
4H	26.4	27.1	26.8	27.4	27.8	26.4	27.1	26.8	27.4	27.8	26.4	27.1
6H	26.7	27.3	27.1	27.6	28.0	26.7	27.3	27.1	27.6	28.0	26.7	27.3
8H	26.8	27.3	27.2	27.7	28.1	26.8	27.3	27.2	27.7	28.1	26.8	27.3
12H	26.8	27.3	27.3	27.7	28.2	26.8	27.3	27.3	27.7	28.2	26.8	27.3
4H	26.5	27.0	26.9	27.4	27.8	26.5	27.0	26.9	27.4	27.8	26.5	27.0
6H	26.8	27.3	27.3	27.7	28.1	26.8	27.3	27.3	27.7	28.1	26.8	27.3
8H	27.0	27.4	27.5	27.8	28.3	27.0	27.4	27.5	27.8	28.3	27.0	27.4
12H	27.1	27.4	27.6	27.9	28.4	27.1	27.4	27.6	27.9	28.4	27.1	27.4
4H	26.5	27.0	26.9	27.4	27.8	26.5	27.0	26.9	27.4	27.8	26.5	27.0
6H	26.8	27.2	27.3	27.7	28.2	26.8	27.2	27.3	27.7	28.2	26.8	27.2
8H	27.0	27.4	27.5	27.8	28.3	27.0	27.4	27.5	27.8	28.3	27.0	27.4

Variation of the observer position for the luminaire distances S

S = 1.0H	+0.4 / -0.6	+0.4 / -0.6
S = 1.5H	+0.9 / -1.7	+0.9 / -1.7
S = 2.0H	+2.0 / -3.1	+2.0 / -3.1

Standard table Correction Summand BK02

BK02


6.3

6.3

Corrected Glare Indices referring to 2500lm Total Luminous Flux

Operator  
Telephone  
Fax  
e-Mail

## Laboratorij / Summary



Height of Room: 2.860 m, Mounting Height: 2.860 m, Maintenance factor:  
0.80

Values in Lux, Scale 1:52

Surface	$\rho$ [%]	$E_{av}$ [lx]	$E_{min}$ [lx]	$E_{max}$ [lx]	$u_0$
Workplane	/	734	493	913	0.671
Floor	20	531	277	813	0.523
Ceiling	70	90	65	104	0.720
Walls (4)	50	188	69	324	/

**Workplane:**  
Height: 0.750 m      **UGR**      Lengthways-      Across      to luminaire axis  
Grid: 32 x 32 Points      Left Wall      13      11  
Boundary Zone: 0.500 m      Lower Wall      12      <10  
(CIE, SHR = 1.00.)

Illuminance Quotient (according to LG7): Walls / Working Plane: 0.235, Ceiling / Working Plane: 0.123.


### Luminaire Parts List

No.	Pieces	Designation (Correction Factor)	$\Phi$ (Luminaire) [lm]	$\Phi$ (Lamps) [lm]	P [W]
1	4	PHILIPS RC120B LED37S/840 W60L60 VAR-PC (1.000)	3693	3700	31.0
			Total: 14773	Total: 14800	124.0

Specific connected load: 7.56 W/m<sup>2</sup> = 1.03 W/m<sup>2</sup>/100 lx (Ground area: 16.40 m<sup>2</sup>)

Operator  
Telephone  
Fax  
e-Mail

## Uklopnica / Summary



Height of Room: 2.860 m, Mounting Height: 2.860 m, Maintenance factor:  
0.80

Values in Lux, Scale 1:62

Surface	$\rho$ [%]	$E_{av}$ [lx]	$E_{min}$ [lx]	$E_{max}$ [lx]	$u_0$
Workplane	/	502	311	576	0.620
Floor	20	379	176	544	0.465
Ceiling	70	63	45	73	0.708
Walls (4)	50	122	48	241	/

**Workplane:**  
Height: 0.750 m      **UGR**      Lengthways-      Across      to luminaire axis  
Grid: 64 x 64 Points      Left Wall      13      11  
Boundary Zone: 0.500 m      Lower Wall      13      12  
(CIE, SHR = 1.00.)

Illuminance Quotient (according to LG7): Walls / Working Plane: 0.215, Ceiling / Working Plane: 0.126.


### Luminaire Parts List

No.	Pieces	Designation (Correction Factor)	$\Phi$ (Luminaire) [lm]	$\Phi$ (Lamps) [lm]	P [W]
1	4	PHILIPS RC120B LED37S/840 W60L60 VAR-PC (1.000)	3693	3700	31.0
			Total: 14773	Total: 14800	124.0

Specific connected load: 4.85 W/m<sup>2</sup> = 0.97 W/m<sup>2</sup>/100 lx (Ground area: 25.57 m<sup>2</sup>)

Operator  
Telephone  
Fax  
e-Mail

## Kupaonica / Summary



Height of Room: 2.860 m, Mounting Height: 2.860 m, Maintenance factor:  
0.80

Values in Lux, Scale 1:31

Surface	$\rho$ [%]	$E_{av}$ [lx]	$E_{min}$ [lx]	$E_{max}$ [lx]	$u_0$
Workplane	/	210	138	266	0.654
Floor	20	121	77	158	0.638
Ceiling	70	31	19	39	0.626
Walls (6)	50	73	21	206	/

### Workplane:

Height: 0.750 m

Grid: 32 x 32 Points

Boundary Zone: 0.500 m

Illuminance Quotient (according to LG7): Walls / Working Plane: 0.353, Ceiling / Working Plane: 0.147.


### Luminaire Parts List

No.	Pieces	Designation (Correction Factor)	$\Phi$ (Luminaire) [lm]	$\Phi$ (Lamps) [lm]	P [W]
1	1	PHILIPS DN130B D217 1xLED20S/840 (1.000)	2275	2500	22.0
			Total: 2275	Total: 2500	22.0

Specific connected load: 3.28 W/m<sup>2</sup> = 1.56 W/m<sup>2</sup>/100 lx (Ground area: 6.71 m<sup>2</sup>)

Operator  
Telephone  
Fax  
e-Mail

## Garderoba za čisto rublje / Summary



Height of Room: 2.860 m, Mounting Height: 2.860 m, Maintenance factor:  
0.80

Values in Lux, Scale 1:42

Surface	$\rho$ [%]	$E_{av}$ [lx]	$E_{min}$ [lx]	$E_{max}$ [lx]	$u_0$
Workplane	/	307	194	396	0.631
Floor	20	208	131	281	0.632
Ceiling	70	57	37	82	0.645
Walls (6)	50	133	42	336	/

### Workplane:

Height: 0.750 m  
Grid: 64 x 32 Points  
Boundary Zone: 0.500 m


Illuminance Quotient (according to LG7): Walls / Working Plane: 0.456, Ceiling / Working Plane: 0.184.

### Luminaire Parts List

No.	Pieces	Designation (Correction Factor)	$\Phi$ (Luminaire) [lm]	$\Phi$ (Lamps) [lm]	P [W]
1	3	PHILIPS DN130B D217 1xLED20S/840 (1.000)	2275	2500	22.0
			Total: 6825	Total: 7500	66.0

Specific connected load: 5.45 W/m<sup>2</sup> = 1.77 W/m<sup>2</sup>/100 lx (Ground area: 12.10 m<sup>2</sup>)

Operator  
Telephone  
Fax  
e-Mail

**Spremište / Summary**

Height of Room: 2.860 m, Mounting Height: 2.860 m, Maintenance factor:  
0.80

Values in Lux, Scale 1:38

Surface	$\rho$ [%]	$E_{av}$ [lx]	$E_{min}$ [lx]	$E_{max}$ [lx]	$u_0$
Workplane	/	172	98	249	0.570
Floor	20	102	62	144	0.606
Ceiling	70	21	15	25	0.688
Walls (4)	50	50	15	101	/

**Workplane:**

Height: 0.750 m  
Grid: 64 x 64 Points  
Boundary Zone: 0.500 m

Illuminance Quotient (according to LG7): Walls / Working Plane: 0.278, Ceiling / Working Plane: 0.123.


**Luminaire Parts List**

No.	Pieces	Designation (Correction Factor)	$\Phi$ (Luminaire) [lm]	$\Phi$ (Lamps) [lm]	P [W]
1	1	PHILIPS DN130B D217 1xLED20S/840 (1.000)	2275	2500	22.0
			Total: 2275	Total: 2500	22.0

Specific connected load: 2.16 W/m<sup>2</sup> = 1.26 W/m<sup>2</sup>/100 lx (Ground area: 10.18 m<sup>2</sup>)

Operator  
Telephone  
Fax  
e-Mail

## Dnevni boravak / Summary



Height of Room: 2.860 m, Mounting Height: 2.860 m, Maintenance factor:  
0.80

Values in Lux, Scale 1:39

Surface	$\rho$ [%]	$E_{av}$ [lx]	$E_{min}$ [lx]	$E_{max}$ [lx]	$u_0$
Workplane	/	259	176	312	0.682
Floor	20	169	110	213	0.649
Ceiling	70	38	28	44	0.735
Walls (4)	50	90	29	204	/

### Workplane:

Height: 0.750 m  
Grid: 64 x 64 Points  
Boundary Zone: 0.500 m


Illuminance Quotient (according to LG7): Walls / Working Plane: 0.341, Ceiling / Working Plane: 0.149.

### Luminaire Parts List

No.	Pieces	Designation (Correction Factor)	$\Phi$ (Luminaire) [lm]	$\Phi$ (Lamps) [lm]	P [W]
1	2	PHILIPS DN130B D217 1xLED20S/840 (1.000)	2275	2500	22.0
			Total: 4550	Total: 5000	44.0

Specific connected load: 3.58 W/m<sup>2</sup> = 1.38 W/m<sup>2</sup>/100 lx (Ground area: 12.30 m<sup>2</sup>)

Operator  
Telephone  
Fax  
e-Mail

**Mikrobiologija / Summary**

Height of Room: 2.800 m, Mounting Height: 2.800 m, Maintenance factor:  
0.80

Values in Lux, Scale 1:67

Surface	$\rho$ [%]	$E_{av}$ [lx]	$E_{min}$ [lx]	$E_{max}$ [lx]	$u_0$
Workplane	/	651	517	756	0.794
Floor	20	447	284	561	0.636
Ceiling	70	80	55	89	0.691
Walls (4)	50	178	60	372	/

**Workplane:**  
Height: 0.750 m      **UGR**      Lengthways-      Across      to luminaire axis  
Grid: 16 x 32 Points      Left Wall      12      10  
Boundary Zone: 0.500 m      Lower Wall      13      11  
(CIE, SHR = 1.00.)

Illuminance Quotient (according to LG7): Walls / Working Plane: 0.255, Ceiling / Working Plane: 0.123.


**Luminaire Parts List**

No.	Pieces	Designation (Correction Factor)	$\Phi$ (Luminaire) [lm]	$\Phi$ (Lamps) [lm]	P [W]
1	3	PHILIPS RC120B LED37S/840 W60L60 VAR-PC (1.000)	3693	3700	31.0
			Total: 11080	Total: 11100	93.0

Specific connected load: 7.11 W/m<sup>2</sup> = 1.09 W/m<sup>2</sup>/100 lx (Ground area: 13.08 m<sup>2</sup>)

Operator  
Telephone  
Fax  
e-Mail

## Kemija / Summary



Height of Room: 2.800 m, Mounting Height: 2.800 m, Maintenance factor:  
0.80

Values in Lux, Scale 1:67

Surface	$\rho$ [%]	$E_{av}$ [lx]	$E_{min}$ [lx]	$E_{max}$ [lx]	$u_0$
Workplane	/	629	423	802	0.672
Floor	20	461	227	671	0.493
Ceiling	70	78	56	90	0.716
Walls (4)	50	157	58	326	/

**Workplane:**  
Height: 0.750 m      **UGR**      Lengthways-      Across      to luminaire axis  
Grid: 32 x 32 Points      Left Wall      12      10  
Boundary Zone: 0.500 m      Lower Wall      13      11  
(CIE, SHR = 1.00.)


Illuminance Quotient (according to LG7): Walls / Working Plane: 0.227, Ceiling / Working Plane: 0.124.

### Luminaire Parts List

No.	Pieces	Designation (Correction Factor)	$\Phi$ (Luminaire) [lm]	$\Phi$ (Lamps) [lm]	P [W]
1	4	PHILIPS RC120B LED37S/840 W60L60 VAR-PC (1.000)	3693	3700	31.0
			Total: 14773	Total: 14800	124.0

Specific connected load: 6.24 W/m<sup>2</sup> = 0.99 W/m<sup>2</sup>/100 lx (Ground area: 19.88 m<sup>2</sup>)

Operator  
Telephone  
Fax  
e-Mail

**Ured / Summary**

Height of Room: 2.800 m, Mounting Height: 2.800 m, Maintenance factor:  
0.80

Values in Lux, Scale 1:40

Surface	$\rho$ [%]	$E_{av}$ [lx]	$E_{min}$ [lx]	$E_{max}$ [lx]	$u_0$
Workplane	/	599	391	753	0.652
Floor	20	407	218	548	0.535
Ceiling	70	67	49	77	0.724
Walls (4)	50	139	51	305	/

**Workplane:**

Height: 0.750 m

Grid: 64 x 32 Points

Boundary Zone: 0.500 m

Illuminance Quotient (according to LG7): Walls / Working Plane: 0.209, Ceiling / Working Plane: 0.112.


**Luminaire Parts List**

No.	Pieces	Designation (Correction Factor)	$\Phi$ (Luminaire) [lm]	$\Phi$ (Lamps) [lm]	P [W]
1	3	PHILIPS RC120B LED37S/840 W60L60 VAR-PC (1.000)	3693	3700	31.0
			Total: 11080	Total: 11100	93.0

Specific connected load: 5.76 W/m<sup>2</sup> = 0.96 W/m<sup>2</sup>/100 lx (Ground area: 16.13 m<sup>2</sup>)

Operator  
Telephone  
Fax  
e-Mail

## Hodnik i stubište / Summary



Height of Room: 2.800 m, Mounting Height: 2.800 m, Maintenance factor:  
0.80

Values in Lux, Scale 1:105

Surface	$\rho$ [%]	$E_{av}$ [lx]	$E_{min}$ [lx]	$E_{max}$ [lx]	$u_0$
Workplane	/	171	95	268	0.554
Floor	20	157	65	264	0.413
Ceiling	70	39	21	72	0.544
Walls (6)	50	91	24	605	/

### Workplane:

Height: 0.000 m  
Grid: 128 x 64 Points  
Boundary Zone: 0.500 m

Illuminance Quotient (according to LG7): Walls / Working Plane: 0.530, Ceiling / Working Plane: 0.229.


### Luminaire Parts List

No.	Pieces	Designation (Correction Factor)	$\Phi$ (Luminaire) [lm]	$\Phi$ (Lamps) [lm]	P [W]
1	5	PHILIPS DN130B D217 1xLED20S/840 (1.000)	2275	2500	22.0
			Total: 11375	Total: 12500	110.0

Specific connected load: 3.27 W/m<sup>2</sup> = 1.91 W/m<sup>2</sup>/100 lx (Ground area: 33.63 m<sup>2</sup>)

Operator  
Telephone  
Fax  
e-Mail

## Uklopnica - panika / Light scene 1 / Anti-panic Surface 1 / Value Chart (E, Perpendicular)




Values in Lux, Scale 1 : 31

Not all calculated values could be displayed.

Position of surface in room:

Marked point:

(7.670 m, 189.000 m, 0.000 m)



Grid: 64 x 64 Points

$E_{av}$  [lx]  
6.03

$E_{min}$  [lx]  
2.69

$E_{max}$  [lx]  
12

$u_0$   
0.446

$E_{min} / E_{max}$   
0.216