

KANAL 3-12

MJ: 1:1000/100


KANAL 3-13

MJ: 1:1000/100

UZDUŽNI PROFILI


KANALI 3-12 i 3-13

MJ 1: 100/1 000



OZNAKA TERENA	114	115	110	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	P24
KOTE TERENA	135.94	136.18	136.24	140.12	140.12	140.18	138.05	139.49	139.55	139.74	139.30	138.96	138.98	139.05	139.19	139.20	139.30	139.47	139.49	139.43
PROFIL CIJEVI	DN 500 mm			DN 300 mm			DN 400 mm			DN 500 mm			DN 600 mm							
KOTE NIVELETE CIJEVI	134.36	134.23	134.10	138.92	138.29	138.15	138.06	137.86	137.82	137.80	137.71	137.62	137.49	137.35	137.24	137.15	137.11	137.10	136.97	136.85
DUBINE NIVELETE	1.58	1.95	2.14	1.60	1.83	2.02	2.12	1.54	1.73	1.94	1.59	1.34	1.49	1.70	1.95	2.04	2.09	2.20	2.52	2.48
KOTE DNA ROVA	134.25	134.12	133.99	138.41	138.18	137.95	137.83	137.64	137.71	137.69	137.60	137.51	137.38	137.24	137.04	136.86	136.88	136.95	136.86	136.84
DUBINE ISKOPA	1.68	2.06	2.25	1.71	1.94	2.23	1.69	1.65	1.84	2.05	1.70	1.45	1.60	1.81	2.15	2.20	2.32	2.52	2.59	2.59
PAD PROFILA U 1/1000	i=3.6‰ L=72.73m			i=5.0‰ L=73.45m			i=2.2‰			i=1.5‰ L=369.32m			i=1.5‰ L=132.48m							
RAZMAK OKANA	36.36	36.36	36.36	46.67	26.78	96.59	8.51	41.44	176.49	36.72	40.30	60.88	63.05	46.52	27.00	8.56	24.61	59.90	12.41	12.41
HORIZONTALNI LOMOVI CIJEVI	180.00°	180.00°	180.00°	232.95°	266.78°	96.59°	181.14°	176.49°	187.13°	270.00°	180.00°	180.54°	180.41°	176.56°	181.64°	136.69°	133.71°	270.00°	180.27°	180.27°
PARCIJALNE DUŽINE	36.36	36.36	36.36	46.67	26.78	96.59	8.51	41.44	176.49	36.72	40.30	60.88	63.05	46.52	27.00	8.56	24.61	59.90	12.41	12.41
STACIONAŽA	0+000.00	0+036.36	0+072.73	0+119.40	0+146.07	0+181.45	0+189.96	0+231.40	0+407.89	0+444.61	0+485.33	0+546.11	0+607.00	0+673.52	0+740.04	0+748.60	0+773.21	0+833.11	0+845.52	0+857.93

LEGENDA:



UZDUŽNI PROFILI

KANALI 3-12 i 3-13

INVESTITOR:

KOPRIVNIČKE VODE d.o.o.
KOPRIVNICA

ZAHVAT U PROSTORU:

SUSTAV ODVODNJE
GRADA KOPRIVNICE

- GLAVNI PROJEKT -

GLAVNI PROJEKTANT:

mr.sc. Petar Marijan, dipl.ing.građ.

PROJEKTANTI:

Dorđe Trbović, dipl.ing.građ.

Krešimir Nekić, dipl.ing.građ.

SURADNICI:

Marija Oliver, mag.ing.aedif.

Marko Škoda, mag.ing.aedif.

Vlatka Bilić, mag.ing.aedif.

DATUM IZRADE:

lipanj, 2017.

BROJ PROJEKTA:

505-K-R/GP

BROJ REVIZIJE:

REV0

MJERILO:

1: 100/1 000

LIST BROJ:

6.11.

hc hidro consult