


KARAKTERISTIČNI PRESJECI ROVA

MJ 1:20







LEGENDA

- ① PJEŠČANA POSTELJICA KRUPNOĆE ZRNA 4-8 mm
- ② OPĆI NASIP (KVALITETAN MIJEŠANI KAMENI MATERIJAL)
- ③ VODOOPSKRBNI CJEVOVOD DN 63 i DN 125 mm
- ④ "SMART HEMISPHERE" MARKER
- ⑤ OBILJEŽAVAJUĆA TRAKA
- ⑥ GORNJI STROJ CESTE

———— IDEALAN PRESJEK ROVA

B - min. širina rova (mm)	dubina ≤ 1.75 m	0.60
	$1.75 \text{ m} < \text{dubina} \leq 4.00$ m	0.70



<p>NACRT:</p> <p style="text-align: center;">KARAKTERISTIČNI PRESJECI ROVA</p>		
<p>INVESTITOR:</p> <p style="text-align: center;">KOPRIVNIČKE VODE d.o.o. KOPRIVNICA</p>	<p>GLAVNI PROJEKTANT :</p> <p>mr.sc. Petar Marijan, dipl.ing.građ.</p> <p style="text-align: center;">  </p>	<p>DATUM IZRADE:</p> <p style="text-align: center;">lipanj, 2017.</p>
<p>ZAHVAT U PROSTORU:</p> <p style="text-align: center;">IZGRADNJA VODOOPSKRBNNE MREŽE NA PERIFERNOM DIJELU GRADA KOPRIVNICE</p> <p style="text-align: center;">- GLAVNI PROJEKT -</p>	<p>PROJEKTANTI:</p> <p>Đorđe Trbović, dipl.ing.građ.</p> <p style="text-align: center;">  </p> <p>Krešimir Nekić, dipl.ing.građ.</p> <p style="text-align: center;">  </p>	<p>BROJ PROJEKTA:</p> <p style="text-align: center;">505-V-P/GP</p> <p>BROJ REVIZIJE:</p> <p style="text-align: center;">REV0</p> <p>MJERILO:</p> <p style="text-align: center;">1: 20</p>
 <p>hidro consult</p>	<p>SURADNICI:</p> <p>Matija Oliver, mag.ing.aedif.</p> <p>Marko Škoda, mag.ing.aedif.</p>	<p>LIST BROJ:</p> <p style="text-align: center;">6.</p>